

# CONFORMITY CERTIFICATE

وفقاً للائحة الصادرة بقرار وزير البلدية والبيئة رقم (١٦٨) لسنة ٢٠١٧ م  
According to the Ministerial Decree No. (168)/2017

PLANT TYPE AND NAME	PLANT NO. 1 Wet Mix, Semix, Command Alkon – C30/377.
CERTIFICATE NO.	RM 846
DATE OF ISSUE:	July. 28, 2021
DATE OF VALIDITY:	July. 27, 2022*
COMPANY NAME:	HBK(REMIX)-HAMAD BIN KHALID READY MIX CO. P.O. Box 31145 Doha-Qatar Tel: 44902628 Fax: 4444902632
PLANT LOCATION.	UMM SALAL, MAZROUAH.
APPLICATION NO.	109912 -2021
SAMPLE ID NO.	QCD-QM-RM/21-CS-16
EVALUATION REPORT NO.	QCD-QM-RM/21-FR-30

## Detail of Evaluation

Aggregates Type.	OPC NORMAL Mixes	SRC NORMAL Mixes	CEMENTITIOUS MATERIALS Mixes	Admixture	@Standards Of Control	
					At Plant	At Lab
-Gabbro • (20 mm) • (10 mm) - Wash Sand	- C 30/20 - C 35/20 - C 45/20	- C 20/20 - C 25/20 - C 40/20	-C45/20 OPC+50%GGBS+5%MS* -C50/20 OPC+60%GGBS+5%MS* -C60/20 OPC+60%GGBS+5%MS*	-Chryso CQ 43 CQ 23 -Epsilone HP 510	At Plant	At Lab
					----	----

**Scope of Audit:** Qatar General Organization for Standardization (Quality and Conformity Department) hereby attests that test results for Samples of materials and mixes as described above conform to the requirements of the standard specifications as per QCS 2014.

**This attestation had based** on the results of tests conducted on random samples selected from the above materials and mixes using sampling procedures given in the specific rules and evaluated as per QCS 2014. **It is applicable** only to the materials and mixes as described in this Certificate and does not cover the entire production of the factory or others branch of the company.

**Responsibility:** Materials and mixes mentioned above or not; shall be check for quality of products at any time according to QCS 2014 with the requirements of the projects and approved by Engineer or Consultant. **All mixes** were marking with (\*) mean Cementitious contents in excess of 400 kg/m<sup>3</sup> and shall not be used unless special consideration has been given to the effect for heat of hydration and reduce thermal stress in the concrete.

**Recommendations @:** In accordance with the principals of (ACI-214) relating to ready-mix concrete factories to the purpose of differentiate between producers and dividing them into classes, or categories as per performance and control of quality.

**Restrictions\*:** It has not permitted to use materials not listed in this certificate without approval from Quality and Conformity Department.

**Condition:** The above ready mixed plant/supplier had founded to be satisfactory at the time of inspection and quality audit (In accordance with Qatar standard regimes and requirements of the QCS 2014) this certificate will remain valid until the Period have shown above, Quality and compliance audits will carry out by Qatar General Organization for Standardization (Quality and Conformity Department) in order to prove that the quality procedure is satisfactory.

## Notes:

1. QS has no any responsibility for supplying of modified or poor quality by the manufacture / supplier during the validity period.
2. It is important to apply two months before expiry date of validity for renewal of this conformity certificate.
3. The required fee for this certificate has been stated according to the decision No. (112)/2019

Recommended by: ..... Authorized by: .....

Head of CC Section

Director of Quality & Conformity Dept.

Approved by: .....

PRESIDENT, QGOS




CONFORMITY CERTIFICATE

# CONFORMITY CERTIFICATE

وفقاً للامانة الصادرة بقرار وزير البلدية والبيئة رقم (١٦٨) لسنة ٢٠١٧ م  
According to the Ministerial Decree No. (168)/2017

PLANT TYPE AND NAME	PLANT NO.02 Wet Mix, MEKA, Command Alkon – CB123891.
CERTIFICATE NO.	RM 847
DATE OF ISSUE:	July. 28, 2021
DATE OF VALIDITY:	July. 27, 2022*
COMPANY NAME:	HBK(REMIX)-HAMAD BIN KHALID READY MIX CO. P.O. Box 31145 Doha-Qatar Tel: 44902628 Fax: 4444902632
PLANT LOCATION.	UMM SALAL, MAZROUAH.
APPLICATION NO.	109905-2021
SAMPLE ID NO.	QCD-QM-RM/21-CS-16
EVALUATION REPORT NO.	QCD-QM-RM/21-FR-30

## Detail of Evaluation

Aggregates Type.	OPC NORMAL Mixes	SRC NORMAL Mixes	CEMENTITIOUS MATERIALS Mixes	Admix.	@Standards Of Control	
					At Plant	At Lab
-Gabbro • (20 mm) • (10 mm)	-C 30/20 -C 35/20	-B 20/20 -C 25/20	-C45/20 OPC+50%GGBS+5%MS* -C50/20 OPC+60%GGBS+5%MS*	-CIKO HY 120	At Plant	At Lab
- Wash Sand	-C 45/20	-C 40/20	-C60/20 OPC+60%GGBS+5%MS*	-Epsilon HP 510	----	----

**Scope of Audit:** Qatar General Organization for Standardization (Quality and Conformity Department) hereby attests that test results for samples of materials and mixes as described above conform to the requirements of the standard specifications as per QCS 2014.

**This attestation had based** on the results of tests conducted on random samples selected from the above materials and mixes using sampling procedures given in the specific rules and evaluated as per QCS 2014. **It is applicable** only to the materials and mixes as described in this certificate and does not cover the entire production of the factory or others branch of the company.

**Responsibility:** Materials and mixes mentioned above or not; shall be check for quality of products at any time according to QCS 2014 with the requirements of the projects and approved by Engineer or Consultant. **All mixes** were marking with (\*) mean Cementitious contents in excess of 400 kg/m3 and shall not be used unless special consideration has been given to the effect for heat of hydration and reduce thermal stress in the concrete.

**Recommendations @:** In accordance with the principals of (ACI-214) relating to ready-mix concrete factories to the purpose of differentiate between producers and dividing them into classes, or categories as per performance and control of quality.

**Restrictions\*:** It has not permitted to use materials not listed in this certificate without approval from Quality and Conformity Department.

**Conditions:** The above ready mixed plant/supplier had founded to be satisfactory at the time of inspection and quality audit (In accordance with Qatar standard regimes and requirements of the QCS 2014) this certificate will remain valid until the period have shown above, Quality and compliance audits will carry out by Qatar General Organization for Standardization (Quality and Conformity Department) in order to prove that the quality procedure is satisfactory.

## Notes:

1. QS has no any responsibility for supplying of modified or poor quality by the manufacture / supplier during the validity period.
2. It is important to apply two months before expiry date of validity for renewal of this conformity certificate.
3. The required fee for this certificate has been stated according to the decision No. (112)/2019

Recommended by:.....

Head of CC Section

Authorized by:.....

Director of Quality & Conformity Dept.

Approved by:.....

PRESIDENT, QGOS



CONFORMITY CERTIFICATE

# CONFORMITY CERTIFICATE

وفقاً لللائحة الصادرة بقرار وزير البلدية والبيئة رقم (١٦٨) لسنة ٢٠١٧ م  
According to the Ministerial Decree No. (168)/2017

PLANT TYPE AND NAME	PLANT NO.03 Wet Mix, MEKA, Command Alkon – CB123892.
CERTIFICATE NO.	RM 848
DATE OF ISSUE:	July. 28, 2021
DATE OF VALIDITY:	July. 27, 2022*
COMPANY NAME:	HBK(REMIX)-HAMAD BIN KHALID READY MIX CO. P.O. Box 31145 Doha-Qatar Tel: 44902628 Fax: 4444902632
PLANT LOCATION.	UMM SALAL, MAZROUAH.
APPLICATION NO.	109888-2021
SAMPLE ID NO.	QCD-QM-RM/21-CS-16
EVALUATION REPORT NO.	QCD-QM-RM/21-FR-30

## Detail of Evaluation

Aggregates Type.	OPC NORMAL Mixes	SRC NORMAL Mixes	CEMENTITIOUS MATERIALS Mixes	Admix.	@Standards Of Control	
					At Plant	At Lab
-Gabbro • (20 mm)	-C 30/20	-B 20/20	-C45/20 OPC+50%GGBS+5%MS*	-CIKO HY 120	At Plant	At Lab
• (10 mm)	-C 35/20	-C 25/20	-C50/20 OPC+60%GGBS+5%MS*			
- Wash Sand	-C 45/20	-C 40/20	-C60/20 OPC+60%GGBS+5%MS*	-Epsilon HP 510	----	----

**Scope of Audit:** Qatar General Organization for Standardization (Quality and Conformity Department) hereby attests that test results for samples of materials and mixes as described above conform to the requirements of the standard specifications as per QCS 2014.

**This attestation had based** on the results of tests conducted on random samples selected from the above materials and mixes using sampling procedures given in the specific rules and evaluated as per QCS 2014. **It is applicable** only to the materials and mixes as described in this certificate and does not cover the entire production of the factory or others branch of the company.

**Responsibility:** Materials and mixes mentioned above or not; shall be check for quality of products at any time according to QCS 2014 with the requirements of the projects and approved by Engineer or Consultant. All mixes were marking with (\*) mean Cementitious contents in excess of 400 kg/m<sup>3</sup> and shall not be used unless special consideration has been given to the effect for heat of hydration and reduce thermal stress in the concrete.

**Recommendations @:** In accordance with the principals of (ACI-214) relating to ready-mix concrete factories to the purpose of differentiate between producers and dividing them into classes, or categories as per performance and control of quality.

**Restrictions\*:** It has not permitted to use materials not listed in this certificate without approval from Quality and Conformity Department.

**Conditions:** The above ready mixed plant/supplier had founded to be satisfactory at the time of inspection and quality audit (In accordance with Qatar standard regimes and requirements of the QCS 2014) this certificate will remain valid until the period have shown above, Quality and compliance audits will carry out by Qatar General Organization for Standardization (Quality and Conformity Department) in order to prove that the quality procedure is satisfactory.

## Notes:

1. QS has no any responsibility for supplying of modified or poor quality by the manufacture / supplier during the validity period.
2. It is important to apply two months before expiry date of validity for renewal of this conformity certificate.
3. The required fee for this certificate has been stated according to the decision No. (112)/2019

Recommended by:..... Authorized by:.....

Head of CC Section

Director of Quality & Conformity Dept

Approved by:.....

PRESIDENT, QGOS



CONFORMITY CERTIFICATE